

Arus nominal starter:

Ukuran starter	Arus nominal pada suhu hingga +55°C, A	Rentang setelan relai beban lebih termal
1	0,13	0,10 – 0,13
	0,17	0,13 – 0,17
	0,23	0,17 – 0,23
	0,31	0,23 – 0,31
	0,41	0,31 – 0,41
	0,55	0,41 – 0,55
	0,74	0,55 – 0,74
	1,00	0,74 – 1,00
	1,30	1,00 – 1,30
	1,70	1,30 – 1,70
	2,30	1,70 – 2,30
	3,10	2,30 – 3,10
	4,20	3,10 - 4,20
	5,70	4,20 - 5,70
	7,60	5,70 - 7,60
	10	7,60 - 10
2	13	10 - 13
	16	13 - 16
	20	16 - 20
	24	20 - 24
	29	24 - 29

Ukuran starter	Arus nominal pada suhu hingga +55°C, A	Rentang setelan relai beban lebih termal
3	35	29 - 35
	38	35 - 38
	42	29 - 42
	52	36 – 52
	63	45 – 63
4	63	45 – 63
	80	60 – 80
	90	65 – 90
5	110	80 – 110
	135	100 – 135
	150	110 - 150
	175	130 – 175
	200	150 – 200
	235	165 – 235
	250	220 - 250

Kotak sambung

Kotak sambung logam

Transformator soket

Panel tombol tekan

Sakelar putar

Sakelar pemilih putar

Sakelar dan soket kabin

Kotak sambung dengan unit proteksi

Kotak daya dengan unit proteksi

Filter peredam interferensi

Starter elektromagnetik

UPS arus bolak-balik

UPS arus searah

Server media

Pasokan dengan penerimaan:

- RMRS
- RRR
- VP

